

|                |                                |                        |                         |
|----------------|--------------------------------|------------------------|-------------------------|
|                |                                | <u>Addendum No.</u>    | <u>003</u>              |
| <u>Project</u> | <u>MSC Electrical Upgrades</u> | <u>Page</u>            | <u>1 of 1</u>           |
|                |                                | <u>Date of Issue</u>   | <u>December 4, 2017</u> |
|                |                                | <u>Project Number</u>  | <u>60556477</u>         |
| <u>Owner</u>   | <u>Town of Inuvik</u>          | <u>Contract Number</u> |                         |
|                |                                | <u>Issued By</u>       | <u>Becki Stewart</u>    |

  

|                     |   |  |                                |
|---------------------|---|--|--------------------------------|
| <b>Distribution</b> | <input checked="" type="checkbox"/> Owner   | <input type="checkbox"/> Resident Engineer | <input type="checkbox"/> Other |
|                     | <input checked="" type="checkbox"/> Bidders | <input type="checkbox"/> File              |                                |

**Instructions**

- Amend your copy of the bid package in accordance with the detail below.
- Retain one (1) copy for your file; sign and return a second copy and attach to your submission as confirmation that the Addendum was taken into account in your bid submission.
- Failure to sign and return this form may result in a non-compliant bid.

**To All Bidders of Record:****1. General**

- 1.1 This Addendum is issued prior to Tender closing to provide for certain revisions as noted herein.
- 1.2 All such revisions will become part of the Work and the effects shall be included in the Tender Price.
- 1.3 All work shall be performed in accordance with the Contract Documents.

**2. REFERENCE SPECIFICATIONS**

- 2.1 As per Part I – Instruction to Bidders, Item 9 and Section 26 32 13 01, Item 2.18.1, the following manufacturers are approved as alternates:
  - 2.1.1 Kohler
  - 2.1.2 MTU/Detroit Diesel.
- 2.2 In Section 26 32 13 01, Power Generation Diesel, delete item 1.1.2.

**3. REFERENCE DRAWINGS**

- 3.1 Revise Drawing E01 as follows: Add the following sentences to the end of Notes 4 and 5: "Arena lighting circuits are 347V, 20A. Arena lights are LED."

**End of Addendum 003**